

### Air Capacity Data for BBE Meeting Rooms

Building Name	Room	Use for Classroom	Description Code	SQ. Feet	Seating Type	Air Exchanges per Hour (ACH) (Total Air Dilevered)	HVAC System Type/Use. R=Recirculated air. NR=No recirculated air
BBB-BECKMAN BIOLOGY LAB	B180	OK w/air purifiers	LECTURE HALL	1,396	FIXED	3.5	R
BBB-BECKMAN BIOLOGY LAB	B101	OK w/air purifiers	CONF/SEM RM	1,124	MOVEABLE	6.1	R
BECKMAN AUDITORIUM	101	OK w/air purifiers	AUDITORIUM	6,220	FIXED	4.9	R
BECKMAN INSTITUTE	115	OK w/air purifiers	CLASS-MOVEABLE	571	MOVEABLE	5.2	R
BECKMAN INSTITUTE	121	OK w/air purifiers	CLASS-MOVEABLE	580	MOVEABLE	5.8	R
BECKMAN INSTITUTE	408	OK w/air purifiers	CONF/SEM RM	499	OTHER	11.6	R
BECKMAN INSTITUTE (BIA)	134	OK w/air purifiers	AUDITORIUM	2,471	FIXED	5.2	R
BRAUN LAB	152	OK w/air purifiers	CONF RM	813	MOVEABLE	8.1	R
BRAUN LAB	320	OK w/air purifiers	CONF RM	605	MOVEABLE	14.7	R
BROAD CENTER	156	OK	CONF RM	228	MOVEABLE	6.1	R
BROAD CENTER	200	OK	CONF RM	799	MOVEABLE	6.0	R
BROAD CENTER	300	OK	CONF	330	MOVEABLE	6.2	R
BROAD CENTER (Rock)	100	OK	LECTURE HALL	1,395	FIXED	4.6	R
CHEN NEUROSCIENCE RESEARCH BLDG	100	OK w/air purifiers	LECTURE HALL	3,286	COMBINATION	2.0	NR (Eco)
CHEN NEUROSCIENCE RESEARCH BLDG	130	OK	SEMINAR ROOM	1,396	COMBINATION	10.0	NR
CHEN NEUROSCIENCE RESEARCH BLDG	240A	OK	CONF RM	589	MOVEABLE	9.4	NR
CHEN NEUROSCIENCE RESEARCH BLDG	340A	OK w/air purifiers	CONF RM	589	MOVEABLE	10.2	NR
KERCKHOFF LAB	119	OK w/air purifiers	LECTURE HALL	1,778	FIXED	3.3	R
KERCKHOFF LAB	101	OK w/air purifiers	CONF RM	578	MOVEABLE	1.1	R
KERCKHOFF LAB	B123	OK	TEACHING LAB	452	FIXED	4.3	NR
KERCKHOFF LAB	B125	OK	TEACHING LAB	255	FIXED	6.7	NR
KERCKHOFF LAB	B127	OK w/air purifiers	TEACHING LAB	517	FIXED	2.1	NR
KERCKHOFF LAB	B136	OK	TEACHING LAB	460	MOVEABLE	17.7	